

# 2021 Water Quality Report for Village of Deckerville

Water Supply Serial Number: 1760

This report covers the drinking water quality for the Village of Deckerville for the 2021 calendar year. This information is a snapshot of the quality of the water that we provided to you in 2021. Included are details about where your water comes from, what it contains, and how it compares to United States Environmental Protection Agency (U.S. EPA) and state standards.

Your water comes from 3 groundwater wells, each 130 feet deep. The State performed an assessment of our source water to determine the susceptibility or the relative potential of contamination. The susceptibility rating is on a seven-tiered scale from "very-low" to "very-high" based on geologic sensitivity, well construction, water chemistry and contamination sources. The susceptibility of our source is Moderately Low.

There are no significant sources of contamination in our water supply. We are making efforts to protect our sources by participating in the wellhead protection program.

If you would like to know more about this report, please contact **Tracy Hoff, DPW Office Building 3550 Rangeline Rd. 810-376-8591 [deckervilledpw@gmail.com](mailto:deckervilledpw@gmail.com)** or visit [www.deckerville.us](http://www.deckerville.us) .

**Contaminants and their presence in water:** Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (800-426-4791).

**Vulnerability of sub-populations:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Center for Disease Control guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

**Sources of drinking water:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As

water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

In order to ensure that tap water is safe to drink, the U.S. EPA prescribes

regulations that limit the levels of certain contaminants in water provided by public water systems. Federal Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.

## Water Quality Data

The table below lists all the drinking water contaminants that we detected during the 2021 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2021. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All the data is representative of the water quality, but some are more than one year old.

Terms and abbreviations used below:

- Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.
- N/A: Not applicable
- TRACE: detectable but too small to measure
- ND: not detectable at testing limit
- ppm: parts per million or milligrams per liter
- ppb: parts per billion or micrograms per liter
- ppt: parts per trillion or nanograms per liter
- pCi/l: picocuries per liter (a measure of radioactivity)
- Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
- Level 1 Assessment: A study of the water supply to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

- Level 2 Assessment: A very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.



1 Monitoring Data for Regulated Contaminants

Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes/No	Typical Source of Contaminant
Arsenic (ppb)	10	0	ND	ND	2017	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	.05	.05	2017	No	Discharge of drilling wastes; Discharge of metal refineries; Erosion of natural deposits
Nitrate (ppm)	10	10	ND	ND	2021	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Fluoride (ppm)	4	4	.78	.78	2021	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Bromoform (ppb)	N/A	N/A	13	13	2021	No	Erosion of natural deposits
THM Total Trihalomethanes (ppb)	80	N/A	19	19	2021	No	Byproduct of drinking water disinfection
HAA5 Haloacetic Acids (ppb)	60	N/A	ND	ND	2021	No	Byproduct of drinking water disinfection
Chlorine (ppm)	4	4	1.26	.51-2.16	2021	No	Water additive used to control microbes
Alpha emitters (pCi/L)	15	0	ND	ND	2020	No	Erosion of natural deposits
Combined radium (pCi/L)	5	0	ND	ND	2020	No	Erosion of natural deposits
Total Coliform (total number or % of positive samples/month)	TT	N/A	Pos	Pos	2021	Yes	Naturally present in the environment
E. coli in the distribution system (positive samples)	See E. coli note <sup>2</sup>	0	ND	N/A	2021	No	Human and animal fecal waste
Fecal Indicator – E. coli at the source (positive samples)	TT	N/A	ND	N/A	2021	No	Human and animal fecal waste

<sup>1</sup> The chlorine "Level Detected" was calculated using a running annual average.

<sup>2</sup> E. coli MCL violation occurs if: (1) routine and repeat samples are total coliform-positive and either is E. coli-positive, or (2) the supply fails to take all required repeat samples following E. coli-positive routine sample, or (3) the supply fails to analyze total coliform-positive repeat sample for E. coli.

**Per- and polyfluoroalkyl substances (PFAS)**

Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes/No	Typical Source of Contaminant
Hexafluoropropylene oxide dimer acid (HFPO-DA) (ppt)	370	N/A	ND		2021	No	Discharge and waste from industrial facilities utilizing the Gen X chemical process
Perfluorobutane sulfonic acid (PFBS) (ppt)	420	N/A	ND		2021	No	Discharge and waste from industrial facilities; stain-resistant treatments
Perfluorohexane sulfonic acid (PFHxS) (ppt)	51	N/A	ND		2021	No	Firefighting foam; discharge and waste from industrial facilities
Perfluorohexanoic acid (PFHxA) (ppt)	400,000	N/A	ND		2021	No	Firefighting foam; discharge and waste from industrial facilities
Perfluorononanoic acid (PFNA) (ppt)	6	N/A	ND		2021	No	Discharge and waste from industrial facilities; breakdown of precursor compounds
Perfluorooctane sulfonic acid (PFOS) (ppt)	16	N/A	ND		2021	No	Firefighting foam; discharge from electroplating facilities; discharge and waste from industrial facilities
Perfluorooctanoic acid (PFOA) (ppt)	8	N/A	ND		2021	No	Discharge and waste from industrial facilities; stain-resistant treatments
<b>Inorganic Contaminant Subject to Action Levels (AL)</b>	<b>Action Level</b>	<b>MCLG</b>	<b>Your<sup>3</sup> Water</b>	<b>Range of Results</b>	<b>Year Sampled</b>	<b>Number of Samples Above AL</b>	<b>Typical Source of Contaminant</b>
Lead (ppb)	15	0	0	ND-.002	2021	0	Lead service lines, corrosion of household plumbing including fittings and fixtures; Erosion of natural deposits
Copper (ppm)	1.3	1.3	.31	ND-.42	2021	0	Corrosion of household plumbing systems; Erosion of natural deposits

<sup>3</sup> Ninety (90) percent of the samples collected were at or below the level reported for our water.

## Additional Monitoring

Unregulated contaminants are those for which the U.S. EPA has not established drinking water standards. Monitoring helps the U.S. EPA determine where certain contaminants occur and whether regulation of those contaminants is needed.

Unregulated Contaminant Name	Average Level Detected	Range	Year Sampled	Comments
Sodium	150	150	2021	Results of monitoring are available upon request
Sulfate	63	63	2021	Results of monitoring are available upon request
Tritium	.6	.6	2019	Manmade radioactive compound from nuclear weapons testing

**Information about lead:** 2020 Consumers Confidence report correction: The 90<sup>th</sup> percentile values for lead & copper were not reported for correctly on the 2020 report. The 2020 value for lead was reported as 1 and should have been 0, the value for copper was reported as .29 and should have been .3. Values listed above are from 2021 testing. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Village of Deckerville is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you have a lead service line it is recommended that you run your water for at least 5 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Monitoring and Reporting to the Department of Environment, Great Lakes, and Energy (EGLE) Requirements: The State of Michigan and the U.S. EPA require us to test our water on a regular basis to ensure its safety. **We were required to take an additional PFAS sample, sampling was taken before 9/30/2021, the sample was taken 6 months late with N/D results.** Possible health effects are: Reproductive effects such as decreased fertility or increased high blood pressure in pregnant women. Developmental effects or delays in children, including low birth weight, accelerated



puberty, bone variations, or behavioral changes. Increased risk of some cancers, including prostate, kidney, and testicular cancers. Reduced ability of the body's immune system to fight infections, including reduced vaccine response. Interference with the body's natural hormones. Increased cholesterol levels and/or risk of obesity.

We will update this report annually and will keep you informed of any problems that may occur throughout the year, as they happen. Copies are available at the Village Office, 2521 Black River St. This report will not be sent to you.

We invite public participation in decisions that affect drinking water quality. Village Council meetings are held the 2<sup>nd</sup> Monday of the month at 2521 Black River St. in the Village Council Chambers. For more information about your water, or the contents of this report, contact Tracy Hoff, 810-376-8591 or visit [www.deckerville.us](http://www.deckerville.us). For more information about safe drinking water, visit the U.S. EPA at <http://www.epa.gov/safewater>.

